

Fairfield Township School  
Excel Template for Lead Results

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
Field ID	Flushed Y/N	Laboratory Sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
1														
2														
3														
4														
5														
6														
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														
21														
22														
23														
24														
25														
26														
27														
28														
29														
30														
31														
32														
33														
34														
35														
36														
37														
38														
39														
40														

Fairfield Township School  
Excel Template for Lead Results

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
41	FTS-Water Fountain D-101	N	P66002	South Jersey Water Test, LLC	08006	5/20/2017	10:28	SM3113B	5/30/2017	13:06	<2.00	<2.00	1	N	
42	FTS-Water Fountain D-103	N	P66003	South Jersey Water Test, LLC	08006	5/20/2017	10:30	SM3113B	5/30/2017	13:25	<2.00	<2.00	1	N	
43	FTS-Water Fountain D-107	N	P66004	South Jersey Water Test, LLC	08006	5/20/2017	10:33	SM3113B	5/30/2017	13:31	<2.00	<2.00	1	N	
44	FTS-Water Fountain D-109	N	P66005	South Jersey Water Test, LLC	08006	5/20/2017	10:34	SM3113B	5/30/2017	13:36	<2.00	<2.00	1	N	
45	FTS-Water Fountain D-111	N	P66006	South Jersey Water Test, LLC	08006	5/20/2017	10:37	SM3113B	5/30/2017	13:42	<2.00	<2.00	1	N	
46	FTS-Water Fountain D-106	N	P66007	South Jersey Water Test, LLC	08006	5/20/2017	10:39	SM3113B	5/30/2017	13:48	<2.00	<2.00	1	N	
47	FTS-Water Fountain D-108	N	P66008	South Jersey Water Test, LLC	08006	5/20/2017	10:40	SM3113B	5/30/2017	13:53	<2.00	<2.00	1	N	
48	FTS-Water Fountain D-112	N	P66009	South Jersey Water Test, LLC	08006	5/20/2017	10:42	SM3113B	5/30/2017	13:58	<2.00	<2.00	1	N	
49	FTS-Water Fountain D-114	N	P66010	South Jersey Water Test, LLC	08006	5/20/2017	10:44	SM3113B	5/30/2017	14:04	<2.00	<2.00	1	N	
50	FTS-Water Fountain E-101	N	P66011	South Jersey Water Test, LLC	08006	5/20/2017	10:47	SM3113B	5/30/2017	14:09	<2.00	<2.00	1	N	
51	FTS-Water Fountain E-103	N	P66012	South Jersey Water Test, LLC	08006	5/20/2017	10:50	SM3113B	5/30/2017	14:15	<2.00	<2.00	1	N	
52	FTS-Water Fountain E-100	N	P66013	South Jersey Water Test, LLC	08006	5/20/2017	10:51	SM3113B	5/30/2017	14:38	<2.00	<2.00	1	N	
53	FTS-Water Fountain E-102	N	P66014	South Jersey Water Test, LLC	08006	5/20/2017	10:53	SM3113B	5/30/2017	14:44	<2.00	<2.00	1	N	
54	FTS-Water Fountain Gym Lobby	N	P66015	South Jersey Water Test, LLC	08006	5/20/2017	10:55	SM3113B	5/30/2017	14:50	<2.00	<2.00	1	N	
55	FTS-Tooth M Outside	N	P66016	South Jersey Water Test, LLC	08006	5/20/2017	10:56	SM3113B	5/30/2017	14:55	11.5	<2.00	1	N	
56	FTS-Ice Maker	N	P66017	South Jersey Water Test, LLC	08006	5/20/2017	10:59	SM3113B	5/30/2017	15:01	<2.00	<2.00	1	N	