




BWSID:	NJ0605323	Water System Type:	Nontransient noncommunity (NTNC)
Water System Name:	FAIRFIELD TOWNSHIP SCHOOL	System Status:	A
Principal County & City:	CUMBERLAND, FAIRFIELD TWP.-0605	System Ownership:	Local govt. or municipal authority
WATER SYSTEM INFORMATION	Total Coliform Results:	Chemical Results:	Monitoring System Facilities Site Visits Violations Other Data
			Source Water Type/Operating Category: GW
			PRINTER FRIENDLY PAGE

Lead/Copper Results for Compliance Period: 07/01/2020--12/31/2020

Lead 20 Samples; 90th %ile: 0 MG/L						Copper 20 Samples; 90th %ile: 0.182 MG/L					
Collection Date	Sample Pt ID	Sample #^	Result*	Analysis Date	Date Received	Collection Date	Sample Pt ID	Sample #^	Result*	Analysis Date	Date Received
12/19/2020	DS	S102299PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102300CU	0.121 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102300PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102301CU	0.114 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102301PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102302CU	0.183 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102302PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102303CU	0.171 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102303PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102284CU	<0.05 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102284PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102285CU	0.053 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102285PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102286CU	0.052 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102286PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102287CU	0.056 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102287PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102288CU	0.066 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102288PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102289CU	0.087 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102289PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102290CU	0.468 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102290PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102291CU	0.091 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102291PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102292CU	0.153 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102292PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102293CU	0.182 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102293PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102294CU	0.138 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102294PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102295CU	0.168 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102295PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102296CU	0.129 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102296PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102297CU	0.177 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102297PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102298CU	0.125 MG/L	12/29/2020	01/06/2021
12/19/2020	DS	S102298PB	<2 UG/L	12/23/2020	01/06/2021	12/19/2020	DS	S102299CU	0.15 MG/L	12/29/2020	01/06/2021

^Rollover sample # to see lab name and ID and METHOD
 *MG/L=milligrams of contaminant per liter of water, equivalent to ppm (parts per million).
 µg/L=micograms of contaminant per liter of water, equivalent to ppb (parts per billion).
 pCi/L=picocuries of contaminant per liter of water—a curie is a measurement of the rate at which a radioactive material decays.
 "<" (less than) means the contaminant cannot be accurately detected below the limit specified; the result can be considered zero.

NJ Primary & Secondary Drinking Water Standards	NJ Dept. of Environmental Protection (NJDEP)	NJDEP ~ Division of Water Supply & Geoscience	USEPA - Groundwater and Drinking Water	Violations (USEPA Encl. 603)
Write suggestions/comments to the webmaster				
Software version number 7.3.17 (11-20-2020)				


 Mark J. Riether, Lab Director



South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 856-875-3506 Phone
 856-875-3507 Fax

www.sjwatertest.com
 NJDEP Certified Lab # 08006



NJ0605323

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



CHAIN OF CUSTODY RECORD

Customer: Fairfield Township Public School - Elementary
Contact: Ron Dipietro
Address: 375 Gouldtown/Woodruff Road
 Bridgeton, NJ 08302
Phone: 856-453-1882 **Fax:** 856-453-7176
Cell: 856-207-3206

Lab ID#	Sample Location	Collection Date	Time	g	Comp	Matrix	Field Measurements	No. of Bottles	Pres.	Analysis Required
S102284	1 st Mechanical Room	12-19-20	8:20 AM	X		D		1X1000		Lead & Copper
S102285	2 nd Kitchen	11	8:42 AM	X		D		1X1000		Lead & Copper
S102286	3 rd Kitchen	11	8:43 AM	X		D		1X1000		Lead & Copper
S102287	4 th Nurse Office	11	8:45 PM	X		D		1X1000		Lead & Copper
S102288	5 th B-110	11	8:46 AM	X		D		1X1000		Lead & Copper
S102289	6 th B-101	11	8:48 AM	X		D		1X1000		Lead & Copper
S102290	7 th A-100	11	8:51 AM	X		D		1X1000		Lead & Copper
S102291	8 th B-117	11	8:54 AM	X		D		1X1000		Lead & Copper
S102292	9 th E-102	11	8:56 AM	X		D		1X1000		Lead & Copper
S102293	10 th Gym Office	11	8:58 AM	X		D		1X1000		Lead & Copper

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GWGROUND WATER SWSURFACE WATER WWMWASTE WATER

Turnaround Time ___ SJWT Standard is 10 work days ___ Rush turnaround available upon request and lab approval _____	Report Format ___ Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	Comments/Special Instructions 		Cooler Temp °C
		Properly Preserved <input checked="" type="radio"/> Yes <input type="radio"/> No		

Sampled by: Ronald Dipietro

Sampled by/Relinquished by: *(Signature)* **Date:** 12-21-20 **Time:** 12:15

Relinquished by: *(Signature)* **Date:** 12/21/20 **Time:** 1355



NJ0605323

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



CHAIN OF CUSTODY RECORD

Customer: Fairfield Township Public School - Elementary
Contact: Ron Dipietro
Address: 375 Gouldtown/Woodruff Road
 Bridgeton, NJ 08302
Phone: 856-453-1882 **Fax:** 856-453-7176
Cell: 856-207-3206

Lab ID#	Sample Location	Collection Date	Collection Time	g g	g g	Matrix	Field Measurements	No. of Bottles	Pres.	Analysis Required
S102294	11 th D101	12-19-20	9:00AM	X		D		1X1000		Lead & Copper
S102295	12 th D-112	11	9:02PM	X		D		1X1000		Lead & Copper
S102296	13 th C-106	11	9:05AM	X		D		1X1000		Lead & Copper
S102297	14 th C-114	11	9:07AM	X		D		1X1000		Lead & Copper
S102298	15 th A-112	11	9:10PM	X		D		1X1000		Lead & Copper
S102299	16 th A-104	11	9:12PM	X		D		1X1000		Lead & Copper
S102300	17 th A-101	11	9:15AM	X		D		1X1000		Lead & Copper
S102301	18 th A-121	11	9:16AM	X		D		1X1000		Lead & Copper
S102302	19 th A-113	11	9:19AM	X		D		1X1000		Lead & Copper
S102303	20 th A-107	11	9:20 ^{AM}	X		D		1X1000		Lead & Copper

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER S: SURFACE WATER W: WASTE WATER

Turnaround Time SJWT Standard is 10 work days Rush turnaround available upon request and lab approval _____	Report Format <input type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions * Sample has taken from bottle -SS 12/21/20		Cooler Temp <input type="checkbox"/> Properly Preserved <input checked="" type="checkbox"/> No
		Date 12-21-20	Time 12:14	

Sampled by: Ronald DiPietro

Sampled by/Relinquished by: *[Signature]*

Relinquished by: *[Signature]*

Date 12-21-20	Time 12:15
Date 12/21/20	Time 1355