



**South Jersey  
Water Test, LLC**

4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

## Fairfield Township Public School

375 Gouldtown-Woodruff Road  
Bridgeton, NJ 08302

### Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
U123395	FTS Water F B1	09/25/2022 09:25	10/4/2022 15:26	<2.00	15.5	SM3113B
U123396	FTS Water F B2	09/25/2022 09:34	10/4/2022 15:26	<2.00	15.5	SM3113B
U123397	B-103 Sink	09/25/2022 09:37	10/4/2022 15:39	<2.00	15.5	SM3113B
U123398	FTS Water F A Wing	09/25/2022 09:41	10/4/2022 15:59	<2.00	15.5	SM3113B
U123399	FTS Water F A Wing	09/25/2022 09:42	10/4/2022 16:06	<2.00	15.5	SM3113B
U123400	A-102 Sink	09/25/2022 09:44	10/4/2022 16:13	<2.00	15.5	SM3113B
U123401	A106 Sink	09/25/2022 09:47	10/4/2022 16:19	<2.00	15.5	SM3113B
U123402	A-110 Sink	09/25/2022 09:49	10/4/2022 16:26	<2.00	15.5	SM3113B
U123403	PS Hallway	09/25/2022 09:53	10/4/2022 16:32	<2.00	15.5	SM3113B
U123404	A-108 Sink	09/25/2022 09:54	10/4/2022 16:52	<2.00	15.5	SM3113B
U123405	A-103 Sink	09/25/2022 09:57	10/4/2022 16:59	<2.00	15.5	SM3113B
U123406	A-109	09/25/2022 09:59	10/4/2022 17:19	<2.00	15.5	SM3113B
U123407	A-119	09/25/2022 10:02	10/4/2022 17:25	<2.00	15.5	SM3113B
U123408	A-117	09/25/2022 10:05	10/4/2022 17:32	<2.00	15.5	SM3113B
U123409	A-111	09/25/2022 10:08	10/4/2022 17:38	<2.00	15.5	SM3113B
U123410	B-115	09/25/2022 10:11	10/4/2022 17:45	<2.00	15.5	SM3113B
U123411	C-Hallway Water F	09/25/2022 10:13	10/4/2022 17:51	<2.00	15.5	SM3113B
U123412	C-101 Sink	09/25/2022 10:16	10/4/2022 17:58	<2.00	15.5	SM3113B
U123413	C-103 Sink	09/25/2022 10:17	10/4/2022 18:04	<2.00	15.5	SM3113B
U123414	C-105 Sink	09/25/2022 10:19	10/4/2022 18:11	<2.00	15.5	SM3113B
U123415	C-107 Sink	09/25/2022 10:21	10/4/2022 18:17	<2.00	15.5	SM3113B
U123416	C-109 Sink	09/25/2022 10:22	10/4/2022 18:37	<2.00	15.5	SM3113B
U123417	C-104 Sink	09/25/2022 10:24	10/4/2022 18:44	<2.00	15.5	SM3113B
U123418	C-108 Sink	09/25/2022 10:26	10/4/2022 18:50	<2.00	15.5	SM3113B
U123419	C-112 Sink	09/25/2022 10:27	10/4/2022 18:57	<2.00	15.5	SM3113B
U123420	C-116 Sink	09/25/2022 10:28	10/4/2022 19:04	<2.00	15.5	SM3113B
U123421	D-103 Sink	09/25/2022 10:31	10/4/2022 19:06	<2.00	15.5	SM3113B
U123422	D-107 Sink	09/25/2022 10:33	10/4/2022 19:30	<2.00	15.5	SM3113B
U123423	D-109 Sink	09/25/2022 10:34	10/4/2022 19:37	<2.00	15.5	SM3113B
U123424	D-111 Sink	09/25/2022 10:35	10/4/2022 19:56	<2.00	15.5	SM3113B
U123425	D-106 Sink	09/25/2022 10:38	10/4/2022 20:03	2.14	15.5	SM3113B
U123426	D-108 Sink	09/25/2022 10:39	10/4/2022 20:09	<2.00	15.5	SM3113B
U123427	D-114 Sink	09/25/2022 10:40	10/4/2022 20:16	<2.00	15.5	SM3113B
U123428	E-101 Sink	09/25/2022 10:43	10/4/2022 20:23	<2.00	15.5	SM3113B
U123429	E-103 Sink	09/25/2022 10:47	10/4/2022 20:29	<2.00	15.5	SM3113B
U123430	Ice Machine	09/25/2022 10:52	10/4/2022 20:36	<2.00	15.5	SM3113B

Units - ug/L = ppb



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

[www.sjwatertest.com](http://www.sjwatertest.com)  
NJ DEP Certified Lab #08006

## **Fairfield Township Public School**

375 Gouldtown-Woodruff Road  
Bridgeton, NJ 08302

### **Results of Lead Analysis**

---

Mark J. Riether, Lab Director

10/05/2022

---

Date



CHAIN OF CUSTODY RECORD

**Customer:** Fairfield Township Public School - Elementary  
**Contact:** Ron Dipietro  
**Address:** 375 Gouldtown/Woodruff Road  
 Bridgeton, NJ 08302  
**Phone:** 856-453-1882  
**Fax:** 856-453-7176  
**Office:** rdipietro@fairfield.k12.nj.us

**South Jersey Water Test, LLC**  
 4077 South Black Horse Pike  
 Williamstown, NJ 08094  
 Phone: 856-875-3506 Fax: 856-875-3507  
 www.sjwatertest.com  
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U123395	FTS water F. B1	9-25-22	9:39 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123396	FTS water F. B2		9:34 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123397	B-103 sink		9:37 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123398	FTS water F. A wing		9:41 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123399	FTS water F. A wing		9:42 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123400	A-102 sink		9:44 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123401	A-106 sink		9:47 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123402	A-110 sink		9:49 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123403	PS Hallway		9:53 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123404	A-108 sink		9:54 AM	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time	Standard	Report Format	Comments/Special Instructions	Cooler Temp
	<input type="checkbox"/> NJ DEP Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	<input type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format		

Sampled by: Ronald Dipietro  
 (Print)

Sampled by/Relinquished by: [Signature]  
 (Signature) Date: 9-26-22 3:30 PM Time: 1530

Relinquished by: \_\_\_\_\_  
 (Signature) Date: \_\_\_\_\_ Time: \_\_\_\_\_

Relinquished by: \_\_\_\_\_  
 (Signature) Date: \_\_\_\_\_ Time: \_\_\_\_\_

CHAIN OF CUSTODY RECORD

**Customer:** Fairfield Township Public School - Elementary  
**Contact:** Ron Dipietro  
**Address:** 375 Gouldtown/Woodruff Road  
 Bridgeton, NJ 08302  
**Phone:** 856-453-1882 **Fax:** 856-453-7176  
**Office:** rdipietro@fairfield.k12.nj.us

**South Jersey Water Test, LLC**  
 4077 South Black Horse Pike  
 Williamstown, NJ 08094  
 Phone: 856-875-3506 Fax: 856-875-3507  
 www.sjwaterest.com  
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U123405	A-103 sink	9-25-22	9:57 AM	D	1 x 250	HNO3*	First Draw Lead	
U123406	A-109		9:59 PM	D	1 x 250	HNO3*	First Draw Lead	
U123407	A-119		10:02 AM	D	1 x 250	HNO3*	First Draw Lead	
U123408	A-117		10:05 AM	D	1 x 250	HNO3*	First Draw Lead	
U123409	A-111		10:08 PM	D	1 x 250	HNO3*	First Draw Lead	
U123410	B-115		10:11 AM	D	1 x 250	HNO3*	First Draw Lead	
U123411	C- Hallway water-F		10:13 AM	D	1 x 250	HNO3*	First Draw Lead	
U123412	C-101 sink		10:16 AM	D	1 x 250	HNO3*	First Draw Lead	
U123413	C-103 sink		10:17 AM	D	1 x 250	HNO3*	First Draw Lead	
U123414	C-105 sink		10:19 AM	D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER W: WASTE WATER

<b>Turnaround Time</b>	<b>Report Format</b>	<b>Comments/Special Instructions</b>	<b>Cooler Temp</b>
<input type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	<input type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	* HNO3 preserved upon receipt at laboratory Yes _____ No _____	_____ °C

**Sampled by:** (Print) Ronald Dipietro

**Sampled by/Relinquished by:** (Signature) [Signature] **Date:** 9-26-22 **Time:** 3:30 PM

**Relinquished by:** (Signature) \_\_\_\_\_ **Date:** \_\_\_\_\_ **Time:** \_\_\_\_\_

**Relinquished by:** (Signature) \_\_\_\_\_ **Date:** \_\_\_\_\_ **Time:** \_\_\_\_\_



CHAIN OF CUSTODY RECORD

**Customer:** Fairfield Township Public School - Elementary  
**Contact:** Ron Dipietro  
**Address:** 375 Gouldtown/Woodruff Road  
 Bridgeton, NJ 08302  
**Phone:** 856-453-1882  
**Fax:** 856-453-7176  
**Office:** rdipietro@fairfield.k12.nj.us

**South Jersey Water Test, LLC**  
 4077 South Black Horse Pike  
 Williamstown, NJ 08094  
**Phone:** 856-875-3506  
**Fax:** 856-875-3507  
 www.sjwaterest.com  
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U123415	C-107 sink	9-25-22	10:21 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123416	C-109 sink		10:22 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123417	C-104 sink		10:24 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123418	C-108 sink		10:26 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123419	C-112 sink		10:27 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123420	C-116 sink		10:28 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123421	D-103 sink		10:31 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123422	D-107 sink		10:33 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123423	D-109 sink		10:34 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123424	D-111 sink		10:35 AM	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AIAQUEOUS SISOIL SLI SLUDGE GW/GROUND WATER SW/SURFACE WATER WW/WASTE WATER

<b>Turnaround Time</b>	<b>Report Format</b>	<b>Comments/Special Instructions</b>	<b>Cooler Temp</b>
<input type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	<input type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	* HNO3 preserved upon receipt at laboratory Yes _____ No _____	_____ °C

**Sampled by:** (Print) Ronald DiPietro

**Sampled by/Relinquished by:** (Signature) [Signature] **Date** 9-26-22 **Time** 3:30 PM

**Relinquished by:** (Signature) \_\_\_\_\_ **Date** \_\_\_\_\_ **Time** \_\_\_\_\_

**Relinquished by:** (Signature) \_\_\_\_\_ **Date** \_\_\_\_\_ **Time** \_\_\_\_\_

CHAIN OF CUSTODY RECORD

**South Jersey Water Test, LLC**  
 4077 South Black Horse Pike  
 Williamstown, NJ 08094  
 Phone: 856-875-3506 Fax: 856-875-3507  
 www.sjwaterest.com  
 NJ DEP Certification #08006

**Customer:** Fairfield Township Public School - Elementary  
**Contact:** Ron Dipietro  
**Address:** 375 Gouldtown/Woodruff Road  
 Bridgeton, NJ 08302  
**Phone:** 856-453-1882 **Fax:** 856-453-7176  
**Office:** rdipietro@fairfield.k12.nj.us

Lab ID#	Sample Location	Collection Date	Time	Lab	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
U123425	D-106 Sink	9:25:22	10:35 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123426	D-108 Sink		10:39 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123427	D-114 Sink		10:40 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123428	E-101 Sink		10:43 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123429	E-103 Sink		10:47 AM	X		D	1 x 250	HNO3*	First Draw Lead	
U123430	Ice Machines		10:52 AM	X		D	1 x 250	HNO3*	First Draw Lead	
				X		D	1 x 250	HNO3*	First Draw Lead	
				X		D	1 x 250	HNO3*	First Draw Lead	
				X		D	1 x 250	HNO3*	First Draw Lead	
				X		D	1 x 250	HNO3*	First Draw Lead	
				X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	<input type="checkbox"/> Standard <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	* HNO3 preserved upon receipt at laboratory Yes _____ No _____	_____ °C

Sampled by: Ronald Dipietro  
 (Print)  
 Sampled by/Relinquished by: [Signature]  
 (Signature) Date: 9-26-22 Time: 1530  
 Relinquished by: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 (Signature)  
 Relinquished by: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 (Signature)

Received by: [Signature] Date: 9/26/22 Time: 1530  
 (Signature)  
 Received by: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 (Signature)  
 Received by: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_  
 (Signature)